

We certify that Dymonic® FC has been tested against ASTM C 920, Standard Specification for Elastomeric Joint Sealants and does conform to the specification requirements and is classified as follows:

Type: S	(Single Component)
Grade: NS	(Non-sag)
Class: 35	(+35% / - 35% joint movement)
Use: NT	(Non-traffic)
M	(Mortar)
A	(Aluminum)
O	(Other)

Dymonic FC has been tested and passed ASTM C 1382, “Standard Test Method for Determining Tensile Adhesion Properties of Sealants when used in Exterior Insulation and Finish Systems (EIFS) Joints.” Third party verification is available upon request.

Additionally, we certify that Dymonic FC has been tested in accordance to ASTM D 412, Test Method for Vulcanized Rubber and Thermoplastic Rubbers and Thermoplastic Elastomers – Tension, with the following results:

Ultimate Elongation: 400%-600%

We further certify that Dymonic FC manufactured by Tremco Incorporated, Cleveland, Ohio conforms to the requirements of Federal Specification TT-S-00230C, Type II, Class A.

Dymonic FC meets CAN/CGSB 19.13, MCG-2-25-B-N.

Although Dymonic FC is not NSF registered, or previously authorized by USDA, it does meet the requirements for use in Federally inspected food processing facilities provided it is not used in areas where food is being processed, prepared or packaged. The material must also be applied in a manner which prevents any direct or indirect contamination of food. Additionally, before any food product can be placed in the area of treatment, the sealant must be allowed to cure according to manufacturer’s recommendations and the area should be sufficiently free of odor to prevent food contamination.

Dymonic FC may be used in registered establishments operating under the **Canadian Food Inspection Agency**. The Canadian Food Inspection Agency has approved Dymonic FC for use in CFIA regulated facilities for situations involving non-food contact.

In addition, Dymonic FC is listed with **Underwriters Laboratories** in the following systems:

FF-D-1063

FW-D-1059

WW-D-1054

HW-D-1054