

CERTIFICATION LETTER

We certify that **Spectrem® 900 SL** has been tested against ASTM C 920, Standard Specification for Elastomeric Joint Sealants and does conform to the specification requirements and is classified as follows:

Type: S (Single Component)
Grade: P (Pourable)
Class: 100/50(+100/- 50% joint movement)
Use: T (Traffic)
M (Mortar)
A (Aluminum)
O (Other)

Spectrem 900 SL has been tested and passed **ASTM D 5893**, "Standard Specification for Cold Applied, Single Component, Chemically Curing Silicone Joint Sealant for Portland Cement Concrete Pavements," Type P (Pourable).

We further certify that **Spectrem 900 SL** conforms to the requirements of the following Federal Specifications:

TT-S-00230C (COM-NBS), Type I, Class A

TT-S-001543A (COM-NBS) Class A

Spectrem 900 SL meets CAN/CGSB-19.13-M87, MCG-2-40-B-N.

Spectrem 900SL has passed **Flame Resistance section of U.S. Federal Specification SS-S-200E**