

CERTIFICATION LETTER

We certify that ExoAir Trio has been tested in accordance with ASTM test methods and the following data are the results of the most recent testing:

ASTM E 90	
STC rating	54
OITC rating	46
ASTM C 518	
Thermal Resistance per inch	3.05 - 3.1 Hr-ft ² -°F/Btu/in
Thermal Conductivity	0.319 - 0.327 Btu-in/hr-ft ² -°F
ASTM E 84	
Flame Spread	5
Smoke Development	150
ASTM E 96	
Dry Cup Method	28.852 Perms
ASTM E 283 before ASTM E2357	0.0014 cfm/ft ² @ 75 Pa
ASTM E 283 after ASTM E2357	0.0017 cfm/ft ² @ 75 Pa