


System No. F-C-3037

August 2008

F Rating — 1 Hr

T Ratings — 0 and 3/4 Hr (See Item 2)
(UL/cUL)



1. **Floor-Ceiling Assembly** — The fire-rated wood joist floor-ceiling assembly shall be constructed of the materials and in the manner specified in the individual L500 Series Floor-Ceiling Designs in the UL Fire Resistance Directory, as summarized below:
 - A. **Flooring System** — Lumber or plywood subfloor with finish floor of lumber, plywood or Floor Topping Mixture* as specified in the individual Floor-Ceiling Design. Max diam of floor opening is 2-3/8 in. (60 mm).
 - B. **Wood Joists** — Nom 2 by 10 in. (51 by 254 mm) lumber joists spaced 16 in. (406 mm) OC with nom 1 by 3 in. (25 by 76 mm) lumber bridging and with ends firestopped. As an alternate to lumber joists, nom 10 in. (254 mm) deep (or deeper) lumber, steel or combination lumber and steel joists, trusses or Structural Wood Members* with bridging as required with ends firestopped.
 - C. **Gypsum Board*** — Nom 4 ft (1.22 m) wide by 5/8 in. (16 mm) thick as specified in the individual Floor-Ceiling Design. Gypsum board nailed to wood joists. Max diam of ceiling opening is 2-3/8 in. (60 mm).
- 1.1 **Chase Wall** — (Not Shown, Optional) - The through penetrant (Item 2) may be routed through a 1 hr fire-rated single, double or staggered wood stud/gypsum wallboard chase wall constructed of the materials and in the manner specified in the individual U300 Series Wall and Partition Designs in the UL Fire Resistance Directory and shall include the following construction features:
 - A. **Studs** — Nom 2 by 4 in. (51 by 102 mm) lumber studs.
 - B. **Sole Plate** — Nom 2 by 4 in. (51 by 102 mm) lumber plates. Max diam of opening is 2-3/8 in. (60 mm).
 - C. **Top Plate** — The double top plate shall consist of two nom 2 by 4 in. (51 by 102 mm) lumber plates. Max diam of opening is 2-3/8 in. (60 mm).
 - D. **Gypsum Board*** — Thickness, type, number of layers and fasteners shall be as specified in individual Wall and Partition Design.
2. **Cables** — One or more cables to be centered within the firestop opening. The annular space between the cable or cable bundle and the edge of the opening shall be 1/2 in. (13 mm). Cables to be rigidly supported on both sides of floor assembly. The following types and sizes of copper conductor cables may be used:
 - A. Seven max three conductor with ground No. 10 AWG (or smaller) cables with polyvinyl chloride (PVC) insulation and jacket.
 - B. One max 100 pair No. 24 AWG (or smaller) cables with polyvinyl chloride (PVC) insulation and jacket.
 - C. **Through Penetrating Product*** — Nom 3/4 in. diam (or smaller) aluminum or steel Flexible Metal Conduit+ with electrical conductors as permitted by the National Electrical Code (NFPA 70).

ALFLEX CORP

- D. Max four aluminum conductor No. 2/0 AWG (or smaller) Type SER service entrance cable with cross-linked polyethylene insulation and PVC jacket.

The T Rating of the firestop system is 3/4 Hr except that when the penetrants in Item 2C and/or 2D above are used, the T Rating is 0 hr.

1. **Firestop System** – The firestop system shall consist of the following:

- A. **Packing Material** – (Optional) – Foam backer rod firmly packed into opening as a permanent form. Packing material to be recessed from top surface of subfloor or sole plate and bottom surface of ceiling or lower top plate of chase wall assembly as required to accommodate the required thickness of fill material.
- B. **Fill, Void or Cavity Material* – Caulk** – Min 1/2 in. (13 mm) thickness of fill material applied within the annulus, flush with top surface of the subfloor or sole plate and bottom surface of ceiling or lower top plate of chase wall assembly. Caulk to be forced into interstices of cable group to max extent possible. Additional fill material to be installed such that a min 1/16 in. (2 mm) crown is formed around the penetrating item and lapping 1/2 in. (13 mm) beyond the periphery of the opening.

TREMCO INC – TREMstop Intumescent Acrylic, FyreCaulk, or TREMstop IA+

*Bearing the UL Classification Mark

+Bearing the UL Listing Mark



Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc.
Copyright © 2008 Underwriters Laboratories Inc. ®

Tremco Commercial Sealants & Waterproofing

3735 Green Road, Beachwood, OH 44122 // Phone: 216.292.5000 // 800.321.7906
220 Wicksteed Avenue, Toronto, ON M4H 1G7 // Phone: 416.421.3300 // 800.363.3213
1451 Jacobson Avenue, Ashland OH 44805 // Phone: 419.289.2050 // 800.321.6357