

TEMPORARY TERMINATION

SEAMS OVERLAPPED 4" MIN. AND SECURED WITH WIDE CROWN BOX STAPLES EVERY 3" O.C. AND WITH NAILS AND WASHERS EVERY 24" O.C. (SEE SEAM DETAILS)

PARASEAL GM/LG, BENTONITE SIDE FACING INSTALLER

SUPERSTOP AT COLD JOINTS, 2" FROM FACE OF WALL

SEAMS OVERLAPPED 4" MIN., TAPED WITH PARA JT TAPE AND COVERED WITH 3" PARASTICK N DRY

12" x 12" PARASEAL DETAIL SHEET; HDPE SIDE FACING INSTALLER

PLACE CEMENT BOARD OVER SOLDIER PILES AT THE AREA TO BE CUT

TREMDRAIN AS SPECIFIED, APPLIED ABOVE WATERTABLE ONLY

ANY VOIDS GREATER THAN 1" IN WIDTH, DEPTH OR HEIGHT SHALL BE REPAIRED WITH NON-SHRINK GROUT, MIN. 24 GAUGE SHEET METAL OR TREATED PLYWOOD (REFER TO APPLICATION INSTRUCTIONS)

PARASEAL GM/LG STARTER STRIP TO EXTEND 6" MIN. BELOW TOP OF FOOTING; HDPE SIDE FACING INSTALLER

REFERENCE SEAM DETAILS

NOTES: PARASEAL PRODUCTS REQUIRE A MIN 24 PSF OF COMPACTION/CONFINEMENT IN ORDER TO FUNCTION AS DESIGNED.

The architecture, engineering, and design of the project using the Tremco products are the responsibility of the project's design professional. All products and systems must comply with local building codes and standards. This detail is for general information and guidance only and Tremco specifically disclaims any liability for the use of this detail. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project. This detail is subject to change without notice. Contact Tremco to ensure you have the most recent version.

Paraseal GM/LG 20 Mil Blindside Walls



Tremco Technical Support: 866-209-2404

Detail: Paraseal GM/LG 20 Mil at Blindside Wall to Below Slab on Grade, HDPE Side Up

Drawn by: KAB

Checked by: WH

Scale: NTS

Date: 3/29/2022

File Name:

BSW-GM20-G-03



Construction Products Group

www.tremcocpg.com